



## **CERTIFICATE OF ANALYSIS**

**REPORTED TO** Stettler, Town of (Alberta)

You know that the sample you collected after

snowshoeing to site, digging 5 meters, and

racing to get it on a plane so you can submit it

to the lab for time sensitive results needed to

make important and expensive decisions

(whew) is VERY important. We know that too.

5031 - 50 Street Stettler. AB TOC 2L0

ATTENTION Grant McQuay WORK ORDER 22G0700

 PO NUMBER
 2605
 RECEIVED / TEMP
 2022-07-07 09:00 / 12.3°C

 PROJECT
 THM+HAA
 REPORTED
 2022-07-14 13:26

PROJECT INFO COC NUMBER No Number

### Introduction:

CARO Analytical Services is a testing laboratory full of smart, engaged scientists driven to make the world a safer and healthier place. Through our clients' projects we become an essential element for a better world. We employ methods conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts. CARO is accredited by the Canadian Association for Laboratories Accreditation (CALA) to ISO/IEC 17025:2017 for specific tests listed in the scope of accreditation approved by CALA.

Big Picture Sidekicks

We've Got Chemistry

It's simple. We figure the more you enjoy working with our fun and engaged team members; the more likely you are to give us continued opportunities to support you.

Ahead of the Curve

Through research, regulation knowledge, and instrumentation, we are your analytical centre for the technical knowledge you need, BEFORE you need it, so you can stay up to date and in the know.

If you have any questions or concerns, please contact me at rpshyk@caro.ca

**Authorized By:** 

Regan Pshyk Junior Account Manager

1-888-311-8846 | www.caro.ca



# **TEST RESULTS**

REPORTED TO Stettler, Town of (Alberta) WORK ORDER 22G0700

PROJECT THM+HAA REPORTED 2022-07-14 13:26

		REPORTED		2022-07-14 13:26	
Result	Guideline	RL	Units	Analyzed	Qualifier
r   Sampled: 2022-07	<b>7-05 08:45</b>				
0.0670	MAC = 0.1	0.00400	mg/L	N/A	
0.0023	N/A	0.0010	mg/L	2022-07-08	
< 0.0010	N/A	0.0010	mg/L	2022-07-08	
0.0647	N/A	0.0010	mg/L	2022-07-08	
< 0.0010	N/A	0.0010	mg/L	2022-07-08	
96		70-130	%	2022-07-08	
86		70-130	%	2022-07-08	
<u> </u>		0.0020	ma/L	2022-07-10	
		2.23=0			
0.0295	N/A	0.0020	mg/L	2022-07-10	
0.0295 0.0342	N/A N/A	0.0020		2022-07-10	
			mg/L		
0.0342	N/A	0.0020	mg/L mg/L	2022-07-10	
	0.0670  0.0023  < 0.0010  0.0647  < 0.0010  96  86  r   Sampled: 2022-07	0.0670 MAC = 0.1  0.0023 N/A  < 0.0010 N/A  0.0647 N/A  < 0.0010 N/A  96 86  r   Sampled: 2022-07-05 08:45	0.0670       MAC = 0.1       0.00400         0.0023       N/A       0.0010         < 0.0010       N/A       0.0010         0.0647       N/A       0.0010         < 0.0010       N/A       0.0010         96       70-130         86       70-130         r   Sampled: 2022-07-05 08:45         0.0034       N/A       0.0020         < 0.0020       N/A       0.0020	Result   Guideline   RL   Units	Result         Guideline         RL         Units         Analyzed           r   Sampled: 2022-07-05 08:45           0.0670         MAC = 0.1         0.00400 mg/L         N/A           0.0023         N/A         0.0010 mg/L         2022-07-08           < 0.0010



### **APPENDIX 1: SUPPORTING INFORMATION**

REPORTED TO Stettler, Town of (Alberta)

PROJECT THM+HAA

WORK ORDER
REPORTED

22G0700

D 2022-07-14 13:26

Analysis Description	Method Ref.	Technique	Accredited	Location
Haloacetic Acids in Water	EPA 552.3*	Liquid-Liquid Microextraction, Derivatization and GC-ECD	✓	Richmond
Trihalomethanes in Water	EPA 5030B / EPA 8260D	Purge&Trap / GC-MSD (SIM)	✓	Edmonton

Note: An asterisk in the Method Reference indicates that the CARO method has been modified from the reference method

#### Glossary of Terms:

RL Reporting Limit (default)

Less than the specified Reporting Limit (RL) - the actual RL may be higher than the default RL due to various factors

MAC Maximum Acceptable Concentration (health based)

mg/L Milligrams per litre

EPA United States Environmental Protection Agency Test Methods

### **Guidelines Referenced in this Report:**

Guidelines for Canadian Drinking Water Quality (Health Canada, June 2019)

Note: In some cases, the values displayed on the report represent the lowest guideline and are to be verified by the end user

#### **General Comments:**

The results in this report apply to the samples analyzed in accordance with the Chain of Custody document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Samples will be disposed of 30 days after the test report has been issued or once samples expire, whichever comes first. Longer hold is possible if agreed to in writing. The quality control (QC) data is available upon request

Results in **Bold** indicate values that are above CARO's method reporting limits. Any results that are above regulatory limits are highlighted **red**. Please note that results will only be highlighted red if the regulatory limits are included on the CARO report. Any Bold and/or highlighted results do <u>not</u> take into account method uncertainty. If you would like method uncertainty or regulatory limits to be included on your report, please contact your Account Manager:rpshyk@caro.ca

Please note any regulatory guidelines applied to this report are added as a convenience to the client, at their request, to help provide some initial context to analytical results obtained. Although CARO makes every effort to ensure accuracy of the associated regulatory guideline(s) applied, the guidelines applied cannot be assumed to be correct due to a variety of factors and as such CARO Analytical Services assumes no liability or responsibility for the use of those guidelines to make any decisions. The original source of the regulation should be verified and a review of the guideline(s) should be validated as correct in order to make any decisions arising from the comparison of the analytical data obtained to the relevant regulatory guideline for one's particular circumstances. Further, CARO Analytical Services assumes no liability or responsibility for any loss attributed from the use of these guidelines in any way.